

# **STABILITY CERTIFICATE**

## **NAME**

**FRANS SCHLOOZ SCHOOL OF EXCELLENCE (CBSE)**

## **Address:**

**DON BOSCO STREET, VARADARAJANPET,  
ANDIMADAM TALUK, ARIYALUR DISTRICT – 621 805.**

## **PERIOD**

**01.06.2025 to 31.05.2028 (3 YEARS)**

## **Er.A. SHEIK MOHAMED**

**B.E., M.I.E., C.E., F.I.V., M.I.N.S.T.,**

**PANEL ENGINEER CLASS-1-A**

**APPROVED BY DISTRICT COLLECTOR**

**APPROVED BY THE PWD, TAMILNADU**

**No.5, 2<sup>nd</sup> FLOOR, TAB COMPLEX,**

**OPP. AMERICAN HOSPITAL,**

**41 BHARATHIDASAN SALAI, CONTONEMENT,**

**TRICHY – 620 001,**

**Mob. No.9025983341, PHONE No.0431-2410283**

## FORM "A"

(Form of application under sub section (1) / Sub section (2) of Section of 4 of the Tamilnadu Public Buildings (Licensing) Act, 1965 (Tamil Nadu Act 13 of 1965) referred to in rule 3 of the Tamilnadu Public Buildings(Licensing) Rules 1966.

From

**FRANS SCHLOOZ SCHOOL OF EXCELLENCE (CBSE)**

**SF.No.94/4 & 94/5, Don Bosco Street,**

**Varadarajanpet, Andimadam Taluk,**

**Ariyalur District – 621 805.**

To

**The Tahsildar,**

**Taluk Office,**

**Andimadam.**

1. Intended/to use the building / to continue to use the existing public buildings / to use the existing building not at present used as a public building / which is situated in the site or plot of land. Town or Revenue Survey No. **SF.No.94/4 & 94/5**, Street or Road **Don Bosco Street, Varadarajanpet** in **Andimadam Taluk** the ward of division / village / Taluk / District **Ariyalur District** and specified in the statement enclosed, as a public-building for a period of **3** years and months from **01.06.2025 to 31.05.2028**.

2. The year of construction and the present approximate cost of construction and purpose for which it is to be used or is being used as Public Buildings are also furnished in the statement accompanying this application

3. I enclose a Chalan for Rs.

4. I also enclose a certificate of Structural Soundness in the prescribed form furnished by the Engineer Thiru.**Er.A.SHEIKMOHAMED**, Chartered Engineer.

(or)

I have not enclosed the certificate of structural soundness from the Engineer.

Dated the

(Signature of the owner of the building)

**CORRESPONDENT**

**FRANS SCHLOOZ SCHOOL OF EXCELLENCE (CBSE)**

**VARADARAJANPET - 621 805**

**ARIYALUR DISTRICT.**

Enclose : 1. Statement

2. Chalan for Rs.

Towards the application fee

Explanation:-Separate application shall be made in respect of each building.

**Er. A.SHEIK MOHAMED,**

B.E., M.I.E., C.E., F.I.V., M.I.N.S.T., M.I.I.P.E.,

M.I.I.P.H.E., M.I.T.A., D.H.M., M.A.(Ling)

**PANEL ENGINEER CLASS 1 – A,**

**Approved by District Collectorate,**

**Approved by the PWD, Tamilnadu.**

**Mobile No.9025983341**

**Phone No. 0431-2410283**

### **STATEMENT ACCOMPANYING FORM "A"**

1. Door Number of building : **FRANS SCHLOOZ SCHOOL OF EXCELLENCE (CBSE)**
2. Location (street Number, ward /Number : **SF.No.94/4 & 94/5,**  
Name of Place ie. Corporation/Municipality/ **Don Bosco Street, Varadarajanpet,**  
Cantonment. **Andimadam Taluk,**  
**Ariyalur District - 621 805.**
3. Year of construction : **2021**
4. Approximate cost of construction : **Rs.120 - 00 Lakhs**
5. Purpose for which the building is being used  
or Proposed to be used. : **Educational Purpose**
6. Purpose for which the building has hitherto  
been used : **Educational Purpose**
7. Details of construction of the building  
(particulars foundation, soil specification  
of the various parts under) : **Gravel Soil**
  1. Foundation : **RCC Column Foundation**
  2. Basement : **Brick Work with Cement Mortar**
  3. Superstructure : **Brick work with Cement Mortar**
  4. Floor and roof are to be given : **Ground Floor, First Floor & Second  
Floor with R.C.C. Roof**
8. Period for which license is required : **3 years (01.06.2025 to 31.05.2028)**
9. Number of Persons to be accommodated : **600 No. of Persons**

**Station: Trichy**

**Date : 26.06.2025**

**Er.A. SHEIK MOHAMED**

**(SIGNATURE OF THE ENGINEER)**

**PANEL ENGINEER CLASS - 1-A**

Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made. I undertake to obtain a fresh licence in case any addition or alteration made to the existing building or portion of building. I also undertake to obtain a fresh licence if the purpose for which the licence was granted for the use of the building or a portion of the building originally is changed or altered subsequently.

**Station:**

**Date :**

**(SIGNATURE OF THE OWNER OF  
THE BUILDING)**

**CORRESPONDENT**

**FRANS SCHLOOZ SCHOOL OF EXCELLENCE (CBSE)**

**VARADARAJANPET - 621 805**

**ARIYALUR DISTRICT.**

**Er. A.SHEIK MOHAMED,**

B.E., M.I.E., C.E., F.I.V., M.I.N.S.T., M.I.I.P.E.,

M.I.I.P.H.E., M.I.T.A., D.H.M., M.A.(Ling)

PANEL ENGINEER CLASS 1 – A,

Approved by District Collectorate,

Approved by the PWD, Tamilnadu.

Mobile No.9025983341

Phone No. 0431-2410283

## FORM "B"

(Form of Certificate of Structural Soundness under sub section (4) of section 4 of the Tamilnadu public buildings (licensing) Act, 1965 (Tamilnadu Act 13 of 1965) referred to in rule 4 of the Tamilnadu Public Buildings (Licensing) Rules 1966.

I certify that I have inspected the building mentioned in the statement and furnish below its salient technical features.

FRANS SCHLOOZ SCHOOL OF EXCELLENCE (CBSE)

SF.No.94/4 & 94/5, Don Bosco Street,

Varadarajanpet, Andimadam Taluk,

Ariyalur District – 621 805.

### (1) Foundation

- |       |                                                                     |                  |
|-------|---------------------------------------------------------------------|------------------|
| (i)   | Depth below ground level                                            | : 1.8 M          |
| (ii)  | Nature of soil met with at foundation Level                         | : Gravel Soil    |
| (iii) | Pressure at foundation                                              | : 13 Ton / Sq.m. |
| (iv)  | Probable safe bearing capacity of the strata met With at foundation | : 20 Ton / Sq.m. |

### (2) Superstructure

- |      |                                                                      |                                                                         |
|------|----------------------------------------------------------------------|-------------------------------------------------------------------------|
| (i)  | Maximum stress in the most critical Section of Masonry and concrete. | Concrete - 5 N / mm <sup>2</sup><br>: Masonry - 2.5 N / mm <sup>2</sup> |
| (ii) | Nature of masonry and concrete and its Safe Permissible stress.      | Concrete - 7 N / mm <sup>2</sup><br>: Masonry - 3.5 N / mm <sup>2</sup> |

The structural soundness of the building has been verified by me with reference to I.S.I. loading standards 875 (Latest Version) and other relevant Indian Standards Code of Practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A licence may be granted for the period from the 01.06.2025 to the 31.05.2028 Inclusive.

Date: 26.06.2025

Signature of the Engineer,

Registration No.

Class.

Address

**ER. A. SHEIK MOHAMED**

**B.E., M.I.E., F.I.V., M.I.N.S.T., M.I.I.P.E**

**PANEL ENGINEER CLASS - 1-A**

(P.T.O)

FRANS SCHLOOZ SCHOOL OF EXCELLENCE (CBSE)  
SF.No.94/4 & 94/5, Don Bosco Street,  
Varadarajanpet, Andimadam Taluk,  
Ariyalur District – 621 805.

# STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

| Location of the building (Door No. St.No. Place of Name)                                                         | Age of the buildings                                     | Value of Building at current rates | No. of Stories                                                                                                                                                                                                                                                                                                                                                                                                                                                        | Short description of structure steel, RCC framed or Load bearing in Masonry       |
|------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------|------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------|
| 1.                                                                                                               | 2.                                                       | 3.                                 | 4.                                                                                                                                                                                                                                                                                                                                                                                                                                                                    | 5.                                                                                |
| Frans Schlooz School of Excellence (CBSE), Don Bosco Street, Varadarajanpet, Andimadam Taluk, Ariyalur District. | 4 Years Old                                              | Rs.120 - 00 Lakhs                  | Ground Floor<br>First Floor<br>Second Floor                                                                                                                                                                                                                                                                                                                                                                                                                           | R.C.C. Framed Structure with R.C.C. Beam and slabs. Brick walls in Cement Mortar. |
| Purpose for which the building is certified for use                                                              | Period for which the building will be structurally sound | No. of persons to be accommodated  | Remarks                                                                                                                                                                                                                                                                                                                                                                                                                                                               |                                                                                   |
| 6.                                                                                                               | 7.                                                       | 8.                                 | 9.                                                                                                                                                                                                                                                                                                                                                                                                                                                                    |                                                                                   |
| Educational Purpose                                                                                              | 3 years                                                  | 600 No. of Persons                 | <p>Building is sound and strong (Other items, buildings are not included in the certificate except this building)</p> <p>Note: Periodical repairs and renovations are to be carried out properly whenever and wherever necessary.</p> <p>Sunshade, Portico, Electrification &amp; Temporary Arrangements should be maintained Properly by the building owner. If any problem comes in the above mater in future in the building owner is the full responsibility.</p> |                                                                                   |

Date: 26.06.2025

Signature of the Engineer

Registration No.

Class. SHEIK MOHAMED

Address. B.E., M.I.E., F.I.V., M.I.N.S.T., M.I.I.P.E.,

PANEL ENGINEER CLASS - 1-A

**Er. A.SHEIK MOHAMED,**

B.E., M.I.E., C.E., F.I.V., M.I.N.S.T.,

M.I.I.P.E., M.I.I.P.H.E., M.I.T.A., D.

PANEL ENGINEER CLASS 1 – A,

Approved by District Collectorate,

Approved by the PWD, Tamilnadu,

Mobile No.9025983341

Phone No. 0431-2410283

### FORM "C"

(Form of Certificate of Structural Soundness under sub-section (4) of section 4 of the Tamilnadu public buildings (licensing) Act, 1965 (Tamilnadu Act of 13 of 1965) referred to in rule 4 of the Tamilnadu Public Buildings (Licensing) Rules, 1966.

I certify that I have inspected the building mentioned in the statement and furnish below its salient technical features.

FRANS SCHLOOZ SCHOOL OF EXCELLENCE (CBSE)

SF.No.94/4 & 94/5, Don Bosco Street,

Varadarajanpet, Andimadam Taluk,

Ariyalur District – 621 805.

#### (1) Foundation

- |       |                                                                     |                  |
|-------|---------------------------------------------------------------------|------------------|
| (i)   | Depth below ground level                                            | : 1.8 M          |
| (ii)  | Nature of soil met with at foundation level                         | : Gravel Soil    |
| (iii) | Pressure at foundation                                              | : 13 Ton / Sq.m. |
| (iv)  | Probable safe bearing capacity of the strata met With at foundation | : 20 Ton / Sq.m. |

#### (2) Superstructure

- |      |                                                                      |                                                                         |
|------|----------------------------------------------------------------------|-------------------------------------------------------------------------|
| (i)  | Maximum stress in the most critical section of Masonry and concrete. | Concrete - 5 N / mm <sup>2</sup><br>: Masonry - 2.5 N / mm <sup>2</sup> |
| (ii) | Nature of masonry and concrete and its safe Permissible stress.      | Concrete - 7 N / mm <sup>2</sup><br>: Masonry - 3.5 N / mm <sup>2</sup> |

The structural soundness of the building has been verified by me with reference to I.S.I. loading standards 875 (Latest Version) and other relevant Indian Standards Code of Practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A licence may be granted for the period from the 01.06.2025 to the 31.05.2028 Inclusive.

Date:26.06.2025

Signature of the Engineer,

Designation

**ER. A. SHEIK MOHAMED**

**B.E., M.I.E., F.I.V., M.I.N.S.T., M.I.I.P.E.,**

**PANEL ENGINEER CLASS 1A (P.T.O)**

FRANS SCHLOOZ SCHOOL OF EXCELLENCE (CBSE)  
SF.No.94/4 & 94/5, Don Bosco Street,  
Varadarajanpet, Andimadam Taluk,  
Ariyalur District – 621 805.

**STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS**

| Location of the building (Door No. St.No. Place of Name)                                                         | Age of the buildings                                     | Value of Building at current rates | No. of Stories                                                                                                                                                                                                                                                                                                                                                                                                                                                        | Short description of structure steel, RCC framed or Load bearing in Masonry       |
|------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------|------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------|
| 1.                                                                                                               | 2.                                                       | 3.                                 | 4.                                                                                                                                                                                                                                                                                                                                                                                                                                                                    | 5.                                                                                |
| Frans Schlooz School of Excellence (CBSE), Don Bosco Street, Varadarajanpet, Andimadam Taluk, Ariyalur District. | 4 Years Old                                              | Rs.120 - 00 Lakhs                  | Ground Floor<br>First Floor<br>Second Floor                                                                                                                                                                                                                                                                                                                                                                                                                           | R.C.C. Framed Structure with R.C.C. Beam and slabs. Brick walls in Cement Mortar. |
| Purpose for which the building is certified for use                                                              | Period for which the building will be structurally sound | No. of persons to be accommodated  | Remarks                                                                                                                                                                                                                                                                                                                                                                                                                                                               |                                                                                   |
| 6.                                                                                                               | 7.                                                       | 8.                                 | 9.                                                                                                                                                                                                                                                                                                                                                                                                                                                                    |                                                                                   |
| Educational Purpose                                                                                              | 3 years                                                  | 600 No. of Persons                 | <p>Building is sound and strong (Other items, buildings are not included in the certificate except this building)</p> <p>Note: Periodical repairs and renovations are to be carried out properly whenever and wherever necessary.</p> <p>Sunshade, Portico, Electrification &amp; Temporary Arrangements should be maintained Properly by the building owner. If any problem comes in the above mater in future in the building owner is the full responsibility.</p> |                                                                                   |

Date: 26.06.2025

Signature of the Engineer

Designation  
**E/A. SHEIK MOHAMEL**  
**B.E.,M.I.E.,F.I.V.,M.I.N.S.T.,M.I.I.P.E.,**  
**PANEL ENGINEER CLASS - 1-A**

**Er. A.SHEIK MOHAMED,**

B.E., M.I.E., C.E., F.I.V., M.I.N.S.T., M.I.I.P.E.,  
M.I.I.P.H.E., M.I.T.A., D.H.M., M.A.(Ling)  
PANEL ENGINEER CLASS 1 – A,  
Approved by District Collectorate,  
Approved by the PWD, Tamilnadu.

Mobile No.9025983341

Phone No. 0431-2410283

**FORM "E"**

(Form of report to be made to the competent authority by Inspecting Authorities of officers appointed under other Acts under section – 28 of the Tamilnadu Public Buildings (Licensing) Act 1966 (Tamilnadu Act 13 of 1965) referred to in Rule 7 of the Tamilnadu Public Buildings (Licensing Rules 1965).

- |                                                                                                                          |                                                                                                                                                                     |
|--------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1. Name and designation of inspecting authority or officer appointed or having jurisdiction under any other              | Er.A. SHEIK MOHAMED,<br>B.E.,M.I.E.,F.I.V.,M.I.N.S.T.,M.I.I.P.E.,<br>: M.I.I.P.H.E.,M.I.T.A.,D.H.M.,M.A.,(Ling)<br>Panel Engineer Class 1 - A<br>Chartered Engineer |
| 2. Location of the building inspected<br>(Door No. Street No. name of place, i.e.,<br>Municipality Town ship, Cantonment | FRANS SCHLOOZ SCHOOL OF EXCELLENCE (CBSE)<br>SF.No.94/4 & 94/5, Don Bosco Street,<br>: Varadarajanpet,<br>Andimadam Taluk,<br>Ariyalur District - 621 805.          |
| 3. Date of Inspection                                                                                                    | : 26.06.2025                                                                                                                                                        |
| 4. Purpose for which the building is used                                                                                | : Educational purpose                                                                                                                                               |
| 5. Nature of defects noticed                                                                                             | : Nil                                                                                                                                                               |
| 6. Suggestion for rectifying defects                                                                                     | : Nil                                                                                                                                                               |
| 7. If in a dangerous condition immediate steps recommended to                                                            | : Nil                                                                                                                                                               |

Place : Trichy

Date : 26.06.2025

(SIGNATURE OF THE INSPECTION AUTHORITY)

ADDRESS:

**Er.A. SHEIK MOHAMED**

**B.E.,M.I.E.,F.I.V.,M.I.N.S.T.,M.I.I.P.E.,**

**PANEL ENGINEER CLASS - 1-A**

**Er. A.SHEIK MOHAMED,**

B.E., M.I.E., C.E., F.I.V., M.I.N.S.T., M.I.I.P.E.,  
M.I.I.P.H.E., M.I.T.A., D.H.M., M.A.(Ling)  
PANEL ENGINEER CLASS 1 – A,  
Approved by District Collectorate,  
Approved by the PWD, Tamilnadu.

Mobile No.9025983341

Phone No. 0431-2410283

**DECLARATION**

I, Er.A. Sheik Mohamed, B.E., M.I.E., F.I.V., M.I.N.S.T., M.I.I.P.E., M.I.P.H.E., M.I.T.A., D.H.M., M.A.(Ling), Chartered Engineer , Govt. Approved Valuer, Panel Engineer Class 1 - A, Son of Late P. Abubacker residing at No. 5, IInd Floor, TAB Complex, Opp. American Hospital, Cantonment, Trichy, do hereby declare that I possess the qualification and experience in the Table 2 Rule 11 of the Tamilnadu Public Building (Licensing) Act 1965 of rule 1966 issuing the Certificate of Structural Soundness of the building covered by the Certificate. Subject to the regular instants.

01. Name and Address


: Er.A. SHEIK MOHAMED,  
B.E., M.I.E., C.E., F.I.V., M.I.N.S.T., M.I.I.P.E.,  
M.I.P.H.E., M.I.T.A., D.H.M., M.A.(Ling),  
Chartered Engineer,  
Panel Engineer Class 1 – A (Proceeding of  
District Collector copy enclosed)  
No.5, IInd Floor, TAB Complex, Opp.American  
Hospital, Cantonement, Trichy – 620 001.

02. Qualification

: B.E., M.I.E., C.E., F.I.V., M.I.N.S.T., M.I.I.P.E.,  
M.I.P.H.E., M.I.T.A., D.H.M., M.A.(Ling),  
Panel Engineer Class 1 – A (Proceeding of the  
District Collector copy enclosed – issuing  
building Stability Certificate for the Cost of the  
Building up to 50 lakhs and above 50 lakhs  
also)

03. No. of the years experience

: More then 30 years in the various building  
activities.

  
Er. A. SHEIK MOHAMED, B.E.,  
Panel Engineer Class 1 – A, (proceeding  
issued by the District collector for issuing  
building Stability certificate for the cost of the  
building upto 50 lakhs and morethen  
50 lakhs also)

**Er.A. SHEIK MOHAMED**  
**B.E., M.I.E., F.I.V., M.I.N.S.T., M.I.I.P.E.,**  
**PANEL ENGINEER CLASS - 1-A**

Proceeding of the District Collector, Ariyalur

Present : Thiru.E Saravanelraj, I.A.S.,

R.Dis.No.6421/2015/C1

Dated : 29.03.2016

Sub : Tamil Nadu Public Building Licensing Act – 1965 – inclusion of name of Thiru.A.Shiek Mohamed in the Panel of Private Practicing Engineer under Class IA (ONE A) – Category in Ariyalur District – Orders Issued.

Ref : 1. Application of Thiru.Shiek Mohamed, B.E., Dated : 20.07.2015.  
2. District Collector, Ariyalur Letter No. 6421/2015/C1 Dated:09.10.2015.  
3. The Engineer – in Chief (Buildings) Chief Engineer (Building) Chennai Region, Chief Engineer (General) PWD Chennai Letter No.AEE/T1/AE /49618/2015 dated:02.03.2016.

**ORDERS:**

Thiru.A.Shiek Mohamed, Chartered Engineer, 5, IInd Floor, Tab Complex, 41 Bharathidasan Salai, Contonment, Trichy has sent an application for enrolling his name in the panel of Engineers of Ariyalur District under class IA(One –A).

- 2) The Engineer-in-chief (Buildings), Chief Engineer (Buildings) Chennai Region, Chief engineer (General), (Public Works Department) Chennai in his letter 2 nd cited has recommended the name of Thiru A.Shiek Mohamed, for the inclusion in the panel of registered Engineers of Ariyalur District.
- 3) The Applicant possesses the Educational and Technical Qualifications and Service as required under. Therefore, it is hereby ordered that the name of Thiru. A.Shiek Mohammed, be included in the panel of Private practicing Engineers under Class IA (one-A) Category (The Building works cost more than Rupees fifty lakhs (Rs.50.00 lakhs) as per the G.O.Ms.No.43, Municipal Administration and Water Supply (MA 4), Department, dated.17.02.2011) in Ariyalur District for issuing structural soundness certificates for Public building works.

(S/d) - E.Saravanelraj,  
District Collector,  
Ariyalur.

/ By Order :

For Collector,   
Ariyalur.

To  
Thiru.A.Shiek Mohamed, B.E.,  
Chartered Engineer,  
No.5 IInd Floor, tab Complex  
41, Bharathidasan Salai, cantonment,  
Trichy.

Copy to : Engineer-in-Chief WRD., and  
Chief Engineer (General), PWD,  
Chepauk, Chennai – 600 005.